

January 30, 2017

Greater Cincinnati Electrical Association
PO Box 18643
Erlanger, KY 41051

RE: GCEA Meeting 1.23.17; MEG Approved Meter Base Questions

At the December meeting two issues were brought up in regards to MEG approved meter bases. Below are the questions and the responses.

- 1) A 200A Milbank meter base was purchased that was MEG approved but it did not have the bypass horns on the terminal blocks.

All customer equipment installed in Duke's service territory must meet all the requirements in the Electric Service Installers Manual. The MEG approved list is everything they have approved, but not all are accepted in Duke's territory. If you find that a supplier is carrying equipment that doesn't meet Duke's requirements please let myself know by emailing me at Austin.bickett@duke-energy.com.

- 2) Can something be done with existing meter base stock that is on the MEG approved list but doesn't have the sticker in it?

Yes, you just need to place the MEG approved list that has the exact meter base listed on it, high light it and place it inside the meter base. The crew will set the meter in these meter bases. If an issue arises please contact the appropriate CPC/Engineering Specialist for that area.

Thank You,

Austin Bickett
(w) 513 287.5638
(c) 513 543.1212
Austin.Bickett@duke-energy.com

cc: Cicely Hart
Vanna Un
Marc Arnold